

JAN 15 1954

25X1A9a

REUR 213 SUBJECT FLASHING. WE BELIEVE SEPARATION BY LEAD
AS SPECIFIED IN PARA 21.8 WILL BE SATISFACTORY AND IF DEMANDED
EXTRA JUSTIFIED IN VIEW OMISSION THIS WORK FROM GENERAL SPECS AND
NON INCLUSION OF SEPARATION UNDER MECHANICAL SPECS. GROUNDING
WOULD NOT HAVE DESIRED EFFECT.

15/2011Z